

LITTLE RIVER ELECTRIC ECI - APPLICATION FOR ENERGY EFFICIENT RATE 2

- ___1. Ceilings have insulation installed having thermal resistance value of R-30 or greater.
- ___2. Walls are exposed to full temperature differential or conditioned are have a total resistance value of R-12 or greater.
- ___3. Floors over crawl space have insulation installed having a resistance value of R-19 or greater.
- ___4. Doors exposed to full TD are weather-stripped and equipped with storm doors or insulated type. Other doors exposed to unconditioned areas are weather-stripped.
- ___5. Air ducts located outside of conditioned space have: All joints mechanically fastened and sealed and a minimum of 2 inches of R-6.5 duct wrap insulation or greater.
- ___6. Attic ventilation is a minimum of one square foot of free area for each 150 square feet of attic area.
- ___7. Chimney flues and fireplaces have tight fitting dampers.
- ___8. Heat pump is controlled by two-stage heating thermostats, the first stage controlling compressor operation and the second stage controlling all auxiliary resistance heaters. Auxiliary heaters are limited to 48 amps each and can be switched so that the energizing of each successive heater is controlled by a separate adjustable outdoor thermostat. A manual switch for by-pass of the first stage and the interlock of the second stage of the heating thermostat is permitted.
- ___9. Total heat loss does not exceed 30 BTUH per square foot of net heated area.

I the undersigned do declare that the above checked statements are true and apply to my home at location _____

Address _____

Account Number _____

Signed _____

Date _____ Witness _____

